

MARKET ASSESSMENT HIGHLIGHTS

Demand, Supply, and Price

- The average weekly demand decreased across all regions.
- The average weekly outage increased in Luzon and Mindanao regions, while it decreased in Visayas region.
- The exports from Luzon to Visayas occurred 81.65% of the time, while the flow from Mindanao to Visayas was observed for 99.95% of the time.
- The average weekly GWAPs decreased by 22.98%, 10.04%, and 9.42% in Luzon, Visayas, and Mindanao regions, respectively.
- The weekly regulating up and down reserves in the Visayas region both showed shortfalls ranging from 0.5% to 63.5% for 09 to 15 December.
- The most frequent congested equipment/line increased to 6.15% this week compared to 3.37% previous week.

Energy Offer Pattern Analysis

Luzon

- Battery storage systems recorded a decrease in offered capacities on 15 December.
- Biofuel plants recorded a decreasing trend in nominated capacities, with dips observed due to an outage from 13 to 15 December.
- Coal plants recorded an increasing trend in offered capacities throughout the week.
- Geothermal plants recorded dips in nominated capacities due to outages on 12 and 15 December.
- Hydro plants decreased their offered capacities as Kalayaan operated its pump on 15 December.
- Natural gas plants recorded decreases in offered capacities due to forced outages.
- Oil plants recorded an increase in offered capacities on 11 December, followed by dips on 12 December.
- Solar and Wind plants' lowest nomination were observed on 10 December and 11 December, respectively.

Visayas

- Battery storage systems recorded dips in offered capacities from 10 to 15 December.
- Biofuel, Hydro and Wind plants had higher nominated capacities compared to the previous week.
- Coal plants recorded an increasing trend in offered capacities throughout the week when major plants went back online from unplanned outages.
- Solar plants' lowest daily peak nomination was observed on 11 December.


Mindanao

- Biofuel plants recorded a decrease in nominated capacities from 12 December until the end of the week, with dips observed on 15 December.
- Hydro plants recorded an increasing trend in offered capacities from 11 December until the end of the week.
- Oil plants recorded dips in offered capacities from 09 to 14 December.
- Solar plants' lowest daily peak nomination was observed on 12 December.

Market Systems Advisory

- No IT-related issue was advised in the IEMOP's market systems from 09 to 15 December 2024.


Capacity Profile




SUMMARY OF AVERAGE VALUES

Particulars	09 - 15 Dec 2024	02 - 08 Dec 2024	% Change
GWAP (Php/MWh)			
System	3,549	4,356	-18.52%
Luzon	3,205	4,162	-22.98%
Visayas	4,390	4,879	-10.04%
Mindanao	4,400	4,857	-9.42%
EFFECTIVE SUPPLY (MW)			
Luzon	12,098	12,213	-0.94%
Visayas	2,358	2,343	0.62%
Mindanao	3,073	3,129	-1.79%
DEMAND (MW)			
Luzon	9,702	9,974	-2.73%
Visayas	1,999	2,019	-1.02%
Mindanao	2,011	2,053	-2.03%
OUTAGE (MW)			
Luzon	2,921	2,828	3.31%
Visayas	352	422	-16.51%
Mindanao	729	722	1.08%
RU PRICE (PHP/MWh)			
Luzon	3,870	7,812	-50.46%
Visayas	21,505	22,446	-4.19%
Mindanao	9,714	7,254	33.92%
RD PRICE (PHP/MWh)			
Luzon	3,740	6,080	-38.49%
Visayas	40,879	41,334	-1.10%
Mindanao	9,714	7,219	34.57%
FR PRICE (PHP/MWh)			
Luzon	2,189	9,301	-76.47%
Visayas	12,833	11,514	11.46%
Mindanao	1,819	1,755	3.68%
DR PRICE (PHP/MWh)			
Luzon	676	827	-18.28%
Visayas	4,099	4,080	0.45%
Mindanao	522	4	11,590.45%


Top 5 Pivotal Plants




HHI




RTD Congestion




Market RSI vs Pivotal Plants



Market Share



ENERGY MARKET PRICES (GWAP)




The charts show the market prices by region based on generator weighted average price (GWAP). Prices are subject to the finalization of settlement data.


■ GWAP

■ GWAP (before post market run calculation)


LUZON SUPPLY AND DEMAND



HVDC FLOW (BETWEEN LUZON AND VISAYAS)




VISAYAS SUPPLY AND DEMAND



HVDC FLOW (BETWEEN VISAYAS AND MINDANAO)




MINDANAO SUPPLY AND DEMAND



The charts show the aggregated supply and demand in each region and the scheduled power flow from/to a particular region via HVDC links.









ENERGY OFFER PATTERN - LUZON



NOTES:









1. In Php (X, Y], it includes offer price greater than Php X but less than or equal to Php Y. 2. Reflected capacity are effective supply, adjusted for the submitted ramp rate and excluding any overriding constraint.

ENERGY OFFER PATTERN - VISAYAS



1. In Php (X, Y], it includes offer price greater than Php X but less than or equal to Php Y.
2. Reflected capacity are effective supply, adjusted for the submitted ramp rate and excluding any overriding constraint.

ENERGY OFFER PATTERN - MINDANAO




NOTES:


1. In Php (X, Y], it includes offer price greater than Php X but less than or equal to Php Y.
2. Reflected capacity are effective supply, adjusted for the submitted ramp rate and excluding any overriding constraint.

CAPACITIES ON OUTAGE PER PLANT TYPE


Luzon



Visayas




Mindanao




CAPACITIES ON OUTAGE PER CATEGORY


Luzon



Visayas







Mindanao



RESERVE MARKET DATA - LUZON

All reserve prices will be capped at price offer cap as per ERC NOR - Case No. 2023-002 RC - PDM Section 2.2.1.4



Reqt vs Sched Legends





- Reserve Requirement
- RU Schedule
- RD Schedule
- FR Schedule
- DR Schedule

Offer Price Range

- PHP 0 and below
- PHP (0,5000]
- PHP (5000,10000]
- PHP (10000,15000]
- PHP (15000,20000]
- PHP (20000,25000]
- PHP (25000,30000]
- PHP (30000,32000]

RESERVE MARKET DATA - VISAYAS

All reserve prices will be capped at price offer cap as per ERC NOR - Case No. 2023-002 RC - PDM Section 2.2.1.4



Req vs Sched Legends





- Reserve Requirement
- RU Schedule
- RD Schedule
- FR Schedule
- DR Schedule

Offer Price Range

- PHP 0 and below
- PHP (0,5000]
- PHP (5000,10000]
- PHP (10000,15000]
- PHP (15000,20000]
- PHP (20000,25000]
- PHP (25000,30000]
- PHP (30000,32000]

RESERVE MARKET DATA - MINDANAO

All reserve prices will be capped at price offer cap as per ERC NOR - Case No. 2023-002 RC - PDM Section 2.2.1.4



Req't vs Sched Legends

- Reserve Requirement
- RU Schedule
- RD Schedule
- FR Schedule
- DR Schedule

Offer Price Range

- PHP 0 and below
- PHP (5000,10000]
- PHP (15000,20000]
- PHP (25000,30000]
- PHP (0,5000]
- PHP (10000,15000]
- PHP (20000,25000]
- PHP (30000,32000]

GLOSSARY OF TERMS

CAPACITY ON OUTAGE

Calculated for each 5-min interval as the sum of the capacity of all generating units on outage, which are further distinguished by plant type and category. The generating unit/s on outage and categories of outage are based on the SO's daily operations report. Cited below are the outage categories as defined in ERC Resolution No. 21, Series of 2016.

- Deactivated Shutdown* - refers to a condition where a generating unit is unavailable for service for an extended period of time for reasons not related to equipment and inactive for more than 60 days.
- Forced Maintenance* - An outage that requires immediate removal of a unit from service, another outage state, or a reserve shutdown state.
- Planned* - An outage that does not require immediate removal from the In-Service state but requires a Unit to be removed from the available state before the next planned outage. This is scheduled at least seven (7) days in advance.
- Planned* - The state in which a Unit is unavailable due to inspection, testing, preventive maintenance or overhaul. A Planned Outage is scheduled with a pre-determined duration and is coordinated with the System Operator. The Planned Outage of a Unit shall be reflected in the Grid Operating and Management Program (GOMP).

DEMAND

Calculated for each 5-minute trading interval as the sum of the real time dispatch (RTD) schedule of all load resources plus regional losses.

EFFECTIVE SUPPLY

Calculated for each 5-minute trading interval as the sum of the offered capacity of all scheduled generators considering their offered ramp rates, nominated loading level of nonscheduled generators and projected output of preferential dispatch generators, adjusted for any over-riding constraints imposed by the System Operator (SO), and reserve offers. Output of generators on testing and commissioning were considered based on the over-riding constraints imposed by the SO.

HERFINDAHL-HIRSCHMAN INDEX (HHI)

It is a commonly accepted measure of market concentration that takes into account the relative size and distribution of participants in the market. The HHI is a number between 0 and 10,000, which is calculated as the sum of squares of the participant's market share. The HHI approaches zero when the market has very large number of participants with each having a relatively small market share. In contrary, the HHI increases as the number of participants in the market decreases, and the disparity in the market shares among the participants increases. The following are the widely used HHI screening numbers: (1) less than 1,500 - not concentrated; (2) 1,500 to 2,500 - moderately concentrated; and (3) greater than 2,500 - highly concentrated.

MARKET RESIDUAL SUPPLY INDEX (Market RSI)

The RSI is a dynamic continuous index measured as ratio of the available generation without a generator to the total generation required to supply the demand. The RSI is measured for each generator. The greater the RSI of a generator, the less will be its potential ability to exercise market power and manipulate prices, as there will be sufficient capacity from the other generators. In contrary, the lower the RSI, the greater the market power of a generator (and its potential benefit of exercising market power), as the market is strongly dependent on its availability to be able to fully supply the demand. In particular, a RSI greater than 100% for a generator means that the remaining generators can cover the demand, and in principle that generator cannot manipulate market price. On the other hand, a RSI less than 100% means that the generator is pivotal in supplying the demand.

The RSI for the whole market (Market RSI) is measured as the lowest RSI among all the generators in the market. A Market RSI less than 100% indicates the presence of pivotal generator/s

MARKET SHARE

The fraction of the total capacity or energy that a company or related group owns or controls in the market.

MAJOR PARTICIPANT GROUP

The grouping of generators by ownership or control.

GLOSSARY OF TERMS**NOMINATED CAPACITY**

The available capacity declared by self-scheduled generators.

OFFERED CAPACITY

The available capacity declared by scheduled generators.

PIVOTAL SUPPLIER INDEX (PSI)

The pivotal supplier index is a binary variable (1 for pivotal and 0 for not pivotal) for each generator. The index identifies whether a generator is pivotal in supplying the demand. The PSI is calculated as the percentage of time that a generator is pivotal in a period (i.e. monthly).

POST MARKET RUN CALCULATION

Price adjustment after consideration of different pricing conditions such as AP, SPC, PSM, and PEN.

REGISTERED CAPACITY

The capacity registered by a generator with WESM.

REGISTERED CAPACITY (NET OF OUTAGE)

The capacity registered by a generator with WESM less capacity on outage.

RESERVE CATEGORIES

Regulating (RU and RD) - Readily available and dispatchable generating capacity that is allocated exclusively to correct deviations from the acceptable nominal frequency caused by unpredicted variations in demand or generation output.

Contingency (FR) - Synchronized generation capacity from Qualified Generating Units and Qualified Interruptible Loads allocated to cover the loss or failure of a synchronized generating unit or a transmission element of the power import from a circuit interconnection.

Dispatchable (DR) - Generating Capacity that are readily available for dispatch in order to replenish the Contingency Reserves whenever a generating unit trips or a loss of a single transmission interconnection occurs.

DISCLAIMER

The information contained in this document is based on the available electricity spot market data. The same information is subject to change as updated figures come in. As such, the PEMC does not make any representation or warranty as to the completeness of this information. The PEMC likewise accepts no responsibility or liability whatsoever for any loss or cost incurred by a reader arising from, or in relation to, any conclusion or assumption derived from the information found herein.